

BATTLE OF THE LABS SCORE CARD

TOTAL SCORE

Group____

Participation (3 Points)

Max 100

5S Organization (0-25 pts)	Lab #'s
Some 10ptsMost 15ptsAll 25pts	
Recording Keeping (2 points each)	
Lab members roster is up to date and posted on a door to one of the labs.	
Emergency Form information on the lab door is correct and up to date.	
<u>General Safety (2 points each)</u>	
Areas around fire extinguishers, electrical panel and safety shower are clear and accessible.	
All objects at least 18 inches away from fire sprinklers even in group's storage areas.	
Lab floors, aisles, and adjacent hallways unobstructed. No trip hazards.	
Extension cords and power strips not daisy chained together, hung over ceiling tile or causing trip hazards.	
Is group aware of the location of the flood response kit.	
Sinks cleaned and eye wash stations have clear access.	
No signs of food or drink in the labs.	
Compressed gas cylinders are secured and the label is visible.	
Hazardous Materials, Wastes, Work Spaces (2 points each)	
Workspaces (benchtops, fume hoods, biosafety cabinets) organized and cleaned.	
Containers, including non-hazardous chemicals and water, labeled.	
Flammable liquids stored in flam cabinets and Acids in Acid cabinets.	
No rusting chemical containers, labels all legible, organized for quicker access.	
Chemical refrigerators clean, no excess unusable samples, appropriately defrosted.	
Oil pumps stored in secondary containment, no oil leaks.	
Base baths are kept clean.	
Chemical waste forms organized and placed in a specific location for use.	
Chemical waste container are kept in a clean area.	
No chemical waste stored in beakers or jars in the hoods.	
Empty bottles, plastics and metal scrap taken to the receiving dock for recycle.	
Bonus Points:	
Specific Lab Safety training/Orientation? (10 Points)	
Standard Operating Procedures? Organized, easily accessible? (10 Points)	
Safety signs, information, accessible safety glasses. (5 Points)	

____Safety Poster participation. (5 points)